

Fire Rated Steel Door



CBRI Tested Steel Door as per BS: 476 Part- 22 IS: 3614 Part- II Single Double Leaf Door Two Hours Rated.

Door Frame- the Door Frames are manufactured from 16 SWG Galvanised Steel Sheet Pressed from to double rebate profile of size 143X57 mm.

Thickness- 46mm.

The Steel Door Fabricated With 2 Nos. 18SWG Galvanized Steel Sheet in between Insulation Material Used.

The Door Frame & Shutter are fitted with SS Ball Bearing Hinges and are coated with one coat of fire resistance material.