

Fire Rated Wooden Door



Class A products with Class A fire ratings

CBRI Tested Wooden Door as per BS: 476 Part- 22 IS: 3614 Part- II Single Double Leaf Door Two Hours Rated.

Door Frame- Door Frame of section 140X 70 mm made of Hard Wood/Teak Wood.

Seal Strip- 15X 4 mm heat activated intumescented. One coat of fire & anti-termite primer.

Door Shutter- Confirming to BS: 476 Part-22 IS: 3614 Part- II Comprising of 12 mm thick Calcium silicate boards sandwiching 25 mm thick proprietary fire resistance insulation material faced with 3 mm commercial ply on both side.

Thickness- 55 mm Smoke Check and fire resistance Door.

Seal Strip- 15X 4 mm heat activated intumescented Fire Seal Strip